



**MANAGEMENT SERVICES DEPARTMENT  
PURCHASING DIVISION**  
241 W. South Street  
Kalamazoo, Michigan 49007-4796  
Telephone (269) 337-8020  
FAX (269) 337-8500  
cokpurchasing@kalamazoocity.org

**ADDENDUM #1**  
December 26, 2019

**TO: ALL MANDATORY Pre-Bid Meeting Attendees**  
**PROJECT: Central Air Stripper Media Replacement**  
**BID REFERENCE #: 91063-001.0**  
**BID OPENING DATE/TIME: January 7, 2020 at 3:00 p.m. Local Time**

The purpose of this addendum is to clarify the Standard Plans and/or Specifications for this project. All work affected is subject to all applicable terms and conditions of the Bidding and Contract Documents.

**FOLLOWING IS INFORMATION FROM THE MANDATORY PRE-BID MEETING HELD AT THE  
CENTRAL WATER TREATMENT PLANT ON TUESDAY, DECEMBER 17, 2019 AT 10:00AM**

**RESPONSE TO QUESTIONS**

**1. Q: How often has the media been replaced?**

A: A small amount of media was replaced when samples of the media were removed for analysis of scale several years ago. Most of the media is original from 1994.

**2. Q: How will the Contractor be able to dispose of water used to clean, rinse, and disinfect?**

A: See specifications, existing drain piping from the air stripper sumps to the sewer is available, but Contractor is responsible for neutralizing and coordinating with Owner to drain to the sewer without overwhelming downstream capacity.

**PRE-BID MEETING HIGHLIGHTED ITEMS**

- 1. Encouraged Contractors to review the available access through the overhead door to the east.**
- 2. Pointed out the location and intended use of the existing acid wash pump.**
- 3. Highlighted need to isolate one air stripper completely (water supply, water effluent, air supply, drains) so that City can continue using the other air stripper.**
- 4. Pointed out need to protect opening in floor to the detention tank from debris during cleaning procedure.**

**In order for a bid to be responsive, this signed addendum must be returned with your bid.** If you have already submitted your bid, acknowledge receipt and acceptance of this addendum by signing in the place provided and returning it to the undersigned and it shall be incorporated in your bid. Please identify your return envelope with the bid reference number and project description.

The Addendum can be viewed and downloaded from the City's website at <https://www.kalamazoo.org/bidopportunities>.

Sincerely,



Michelle Emig  
*Purchasing Division Manager*

- c: Eric Sajtar, Public Services
- Steve Skalski, Public Services
- Anna Crandall, Public Services
- Prevailing Wage File

FIRM: \_\_\_\_\_

SIGNED: \_\_\_\_\_

NAME: \_\_\_\_\_

(Type or Print)

DATE: \_\_\_\_\_